



Building & Safety
Department

I
N
F
O
R
M
A
T
I
O
N
A
L

B
U
L
L
E
T
I
N

No. 105

Rev 03/09

Pg 1 of 1

30001 Ladyface Court
Agoura Hills, CA 91301
Phone: (818) 597-7334
Fax: (818) 597-7352
www.ci.agoura-hills.ca.us



Lighting Mandatory Measures



- L1 Each room is equipped with a separate manual switch or occupancy sensor device. All manual switches are located so that personnel can see the controlled area when operating the switches.
- L2 All rooms greater than 100 square feet and with more than 1.0 watts per square foot of lighting load shall be controlled with bi-level switching for uniform reduction of lighting within the room.
- L3 All rooms that are greater than 250 square feet and have windows and skylight that allow for the effective use of daylight in the area shall have 50% or the lamps in each day lit area controlled by a separate switch.
- L4 All fluorescent fixtures shall be certified by the manufacturer and listed in the directory of certified luminaries and ballast.
- L5 All one and three lamp fluorescent fixtures and tandem wired with two (2) lamp ballast where required by #132 of the energy efficiency standards.
- L6 All automatic control devices specified are certified and installed as directed by the manufacturer.
- L7 Display lighting is separately switched on circuits that are 20 AMPS or less.
- L8 The building lighting shutoff control system consists of an automatic time switch for each floor or each 5,000 square foot zone.
- L9 Exterior mounted fixtures served from inside the building are controlled with a directional photocell control.

For more information refer to the **California Electrical Code** and the **Standard for Residential & Non-Residential Energy Manual** by the California Energy Commission.